

AMENDMENT NO. 1 MARCH 2020

TO

**IS 636 : 2018 NON-PRECOLATING FLEXIBLE FIRE
FIGHTING DELIVERY HOSE — SPECIFICATION**

(Fourth Revision)

(Page 1, clause 1.1, NOTE 3) — Substitute ‘ANNEX G’ for ‘ANNEX H’.

(Page 1, clause 1.1, NOTE 4) — Substitute ‘ANNEX J’ for ‘ANNEX I’.

(Page 8, clause D-4.3) — Substitute the following for the existing clause:

‘D-4.3 Place the test piece in the water bath, maintained at $20 \pm 5^{\circ}\text{C}$, and clamp the ends of the test piece so that test piece is completely horizontal and the marks are in level with the surface of the water as well as the entire length of test piece within the marks is immersed.’

(Page 10, clause F-2.1, line 6) — Substitute ‘Fig. 3’ for ‘Fig. 1’.

(Page 10, clause F-2.1, line 7) — Substitute ‘Fig. 4’ for ‘Fig. 2’.

(Page 10, clause F-2.4, line 3) — Substitute ‘Fig. 5’ for ‘Fig. 3’.